



DEVELOPMENT SERVICES – BUILDING INSPECTION

NON-RESIDENTIAL CONSTRUCTION POWER

PLEASE REFER TO THE "PROCESS" SECTION ON PAGE 2 FOR INSTRUCTIONS.

Project Address: _____ Permit Number: _____

Please provide explanation for request:

Electrical service to advance construction activity and testing.

Other: _____

Include the following information:

- A lock-out/tag-out (LOTO) procedure per Cal/OSHA.
- A single-line diagram for the construction power only.

AGREEMENT/DISCLOSURE

We understand and agree that the City of Palo Alto reserves the right to disconnect the **electric** service if any violation of city codes or ordinances is not corrected immediately upon request or if any portion of the structure is occupied prior to approval.

We are familiar with the California Electrical Code Article 590 (Temporary Installations) and Cal/OSHA Title 8 and will comply with the requirements therein.

Contractor/agent, please initial and date here: _____

We, the undersigned, have read this agreement and fully understand and agree to all conditions herein.

Name of Owner/Tenant

Signature of Owner/Tenant

Contractor/Agent


Signature of Contractor/Agent

Field Contact Phone Number

Field Contact Email Address

Please check with staff for the latest fee amount.

PROCESS



QUESTIONS

Are you using the existing service? Yes
 No

If construction power is being provided from an adjacent facility, has CPAU Electric Engineering approved the connection? Yes (If so, provide email correspondence)
 No (Make sure to obtain approval prior to re-inspection; call CPAU Electric Engineering at 650-566-4501)
 Not Applicable

INSPECTION

Date	Inspector Number	Inspector Initials
------	------------------	--------------------

CONSTRUCTION POWER USING NEW OR EXISTING ELECTRICAL SERVICE (INSPECTION 108)

- Grounding electrode system is complete.
- Only GFCI breakers are installed for construction use.
- Inspector has witnessed torquing.

ADDITIONAL CORRECTIONS/NOTES

Date: _____ Inspector Number: _____ Inspector Initials: _____

RELEASE TAG STRING (If Applicable) _____
