



DEVELOPMENT SERVICES – BUILDING INSPECTION

RESIDENTIAL CONDITIONAL METER RELEASE OR CONSTRUCTION POWER

PLEASE REFER TO THE "PROCESS" SECTION ON PAGE 2 FOR INSTRUCTIONS.

Project Address: _____ Permit Number: _____

Please provide explanation for request:

- Electrical Service to advance construction activity and testing.
Gas Service to provide conditioned space and appliance testing.
Other: _____

Select only ONE of the following:

- Conditional Gas Service
Conditional Electrical Service
Construction power using new or existing service

AGREEMENT/DISCLOSURE

We fully understand and agree that this building will NOT BE OCCUPIED FOR ANY REASON until occupancy has been granted. I further understand and agree that the City of Palo Alto reserves the right to disconnect the electric or gas service if any violation of city codes or ordinances is not corrected immediately upon request or if any portion of the structure is occupied prior to approval.

We are familiar with the California Electrical Code Article 590 (Temporary Installations) and Cal/OSHA Title 8 and will comply with the requirements therein.

Contractor/agent, please initial and date here: _____

We, the undersigned, have read this agreement and fully understand and agree to all conditions herein.

Name of Owner/Tenant

Signature of Owner/Tenant

Contractor/Agent


Signature of Contractor/Agent

Field Contact Phone Number

Field Contact Email Address

Please check with staff for the latest fee amount.

PROCESS



INSPECTION

CONDITIONAL GAS SERVICE (INSPECTION 109)

Date	Inspector Number	Inspector Initials	<input type="checkbox"/> All gas appliances are installed and functional (gas cook tops and free standing ranges are not required to be installed), but the outlets must have a valve and be capped.
			<input type="checkbox"/> Physical protection is in place to protect the gas meter from construction activities.
			<input type="checkbox"/> Whole house gas test is witnessed by inspector.
			<input type="checkbox"/> Green tag (by WWG) is on gas stub out.

CONDITIONAL ELECTRICAL SERVICE (INSPECTION 108)

Date	Inspector Number	Inspector Initials	<input type="checkbox"/> All receptacles and outlets are made up and covered.
			<input type="checkbox"/> Inspector has witnessed torquing.

CONSTRUCTION POWER USING NEW OR EXISTING SERVICE IS SELECTED (INSPECTION 108)

Date	Inspector Number	Inspector Initials	<input type="checkbox"/> Grounding electrode system is complete.
			<input type="checkbox"/> Only GFCI circuit breakers are installed for construction use.
			<input type="checkbox"/> Inspector has witnessed torquing.

ADDITIONAL CORRECTIONS/NOTES

Date: _____ Inspector Number: _____ Inspector Initials: _____

RELEASE TAG STRING
