


- SPECIFICATIONS**
1. Precast M.H. sections shall conform to applicable provisions of ASTM C76-59T.
  2. Steps shall be galvanized steel, 3/4" dia, plastic coated, and inserted 3" min.

U-shaped channel may be formed in M.H. base or constructed by laying pipe through the M.H. and breaking out top half of the pipe and forming remainder of U-shaped channel in concrete.

Rev	By	Date
0	PAP	12/14/92
1	MAR	01/02/02
2	RTN	06/07/17

**Manhole  
Standard Precast  
Smaller than 36"**

Approved by:   
 PE No. 72158  
 Date 01/10/18

Scale: NTS

City of Palo Alto Standard

Dwg No. 312