



SPECIFICATIONS

1. Precast M.H. sections shall conform to applicable provisions of ASTM C-478.
2. Steps shall be galvanized steel, 3/4" dia., plastic coated and inserted 3: min.

U-shaped channel may be formed in M.H. base or constructed by laying pipe through the M.H. and breaking out top half of the pipe and forming remainder of U-shaped channel in concrete.

Rev	By	Date
0	PAP	12/14/92
1	MAR	01/02/02
2	JT	07/31/06
3	RTN	08/08/17

Scale: NTS

**Storm Manhole
Standard Precast Pipe
36" and Larger**

City of Palo Alto Standard

Approved by:

PE No. 72158

Date 01/10/18

Dwg No. **313**