

NOTES:


- Rigid plastic, A.C., C.I., or steel pipe allowed to box from pump.
- Box shall be set with adjacent grades sloping away to prevent rainwater and landscape water from entering.
- Box shall be set in landscaped area to facilitate percolation.
- Box shall not have concrete bottom to facilitate percolation.
- Box must be located at least 10 ft. from all property lines.

Rev	By	Date
0	HQN	10/04/06
1	RTN	06/08/17

Scale: NTS

Bubbler Box

City of Palo Alto Standard

Approved by: 

PE No. 72158

Date 01/10/18

Dwg No. **323**