

NOTES:


- Reinforced sidewalk located by engineer.
- All other standard sidewalk details apply.
- Welded wire mesh shall be 6x6 w 4.0/4.0 and free of oil, dirt and defects and protected from damage. Wire splices shall overlap 12 inches and be tied together and supported in position.

Rev	By	Date
1	RTN	08/11/17

Scale: NTS

Reinforced Sidewalk

City of Palo Alto Standard

Approved by: 

PE No. 72158

Date 01/10/18

Dwg No. 604A