



SIDE VIEW

FRONT VIEW

DIMENSION "A" : 7" MINIMUM FOR RESIDENTIAL METERS. 15" MAXIMUM
 9" MINIMUM FOR COMMERCIAL AND APARTMENT METERS. 15" MAXIMUM

DIMENSION "B" : 7" MINIMUM FOR RESIDENTIAL METERS.
 9" MINIMUM FOR COMMERCIAL AND APARTMENT METERS.

DIMENSION "C" : 2-1/2" MINIMUM FOR RESIDENTIAL METERS.
 5" MINIMUM FOR COMMERCIAL AND APARTMENT METERS.

NOTE: DIMENSION "A" APPLIES ONLY TO THAT PORTION OF THE CABINET ENCLOSING DOOR IN FRONT OF THE METER.

NOTE:

1. THE CABINET SHOULD BE DESIGNED SO THAT NEITHER THE ROOF NOR THE DOOR SUPPORTS INTERFERE WITH THE INSTALLATION OF THE METER.
2. AT LEAST 16" VERTICAL AND HORIZONTAL CLEAR SPACE SHALL BE PROVIDED DIRECTLY IN FRONT OF THE SOCKET (8" ABOVE AND BELOW, AND 8" ON EITHER SIDE OF THE CENTER OF THE METER SOCKET).
3. THE CABINET DOORS SHALL HAVE SIDE HINGES, WILL OPEN GREATER THAN 90 DEGREES, AND WILL HAVE A LATCH TO KEEP IT IN THE OPEN POSITION.
4. METER CABINET ENCLOSURES INSTALLED IN LOCATIONS SUSCEPTIBLE TO VEHICULAR DAMAGE MUST COMPLY WITH THE REQUIREMENTS OF CPAU STD DWG SR-MT-E-1035.

APPROVED _____ 199	ENGINEERING STANDARD				
<i>Original Signed and Approved by Engineering Manager</i> ENGR. MANAGER _____ DRAWN BY _____ CHECKED BY _____	CLEARANCE FOR METER CABINET ENCLOSURES CITY OF PALO ALTO CALIFORNIA	2	3/16	ADDED NOTE 4	TT
		1	11/08	REVISED NOTES AND DIMENSIONS	TT
		REV	DATE	DESCRIPTION	APPR
		NTS	SR-MT-E-1013	1 OF 1	
		SCALE	STANDARD NO.	SHEET NO.	