



- ① CHECK VALVE
- ② PRESSURE REGULATED RELIEF VALVE
- ③ DUMP OUTLET
- ④ TEST COCK, 4 REQUIRED
- ⑤ GATE VALVE OR BALL VALVE
- ⑥ 90° ELBOW
- ⑦ FLANGE OR UNION
- ⑧ DUCTILE IRON OR COPPER PIPE
- ⑨ BURIED JOINTS SHALL BE PLASTIC WRAPPED FLANGE & CORE TEN BOLTS OR MEGALUG

NOTES:

1. ALL DEVICES SHALL BE APPROVED BY WATER-GAS-WASTEWATER UTILITIES DEPARTMENT.
2. THE DEVICE SHALL BE INSTALLED ON THE OWNER'S PROPERTY AND ADJACENT TO THE METER.
3. INSPECTION BY UTILITIES CROSS CONNECTION IS REQUIRED FOR SUPPLY PIPE BETWEEN THE METER AND THE VALVES.
4. APPROVED RPPA ASSEMBLIES, SEE SECTION O2660. OF THESE STANDARDS

BY	DATE	REDUCED PRESSURE PRINCIPLE ASSEMBLY - RPPA STANDARD DETAIL	APPROVED: OCTOBER, 30 1992 <i>Roger Cwiak</i> 34533 ROGER CWIAK R.E. NO. CHIEF ENGINEER	SCALE: NONE
DRAWN	J.J. 8/92		REVISION: JUNE 8, 1998	DWG. NO. STD. WD-17
CHECKED	J.J. 8/92			APPENDIX B
REVIEWED	R.E. 4/98	CITY OF PALO ALTO, CALIFORNIA		

11/1