



NOTES:

1. PARALLEL RPPA ASSEMBLIES SHALL BE USED IN ALL LOCATIONS WHERE THE WATER CAN NOT BE INTERRUPTED DURING NORMAL WORKING HOURS.
2. FOR INSTALLATION AND MATERIALS REQUIREMENTS REFER TO DWG. STD WD-17 OF THESE STANDARDS
3. ALL DEVICES SHALL BE APPROVED BY WATER-GAS-WASTEWATER UTILITIES DEPARTMENT.
4. THE DEVICE SHALL BE INSTALLED ON THE OWNER'S PROPERTY AND ADJACENT TO THE METER.
5. INSPECTION BY UTILITIES CROSS CONNECTION IS REQUIRED FOR SUPPLY PIPE BETWEEN THE METER AND THE VALVES.
6. FOR APPROVED RPPA ASSEMBLIES, SEE SECTION 02660 OF THESE STANDARDS.

BY	DATE	PARALLEL REDUCED PRESSURE PRINCIPLE ASSEMBLIES STANDARD DETAIL	APPROVED: JULY, 15 1998	SCALE: NONE
DRAWN	R.E. 7/98		<i>Roger Cwiak</i> 34533 ROGER CWIAK CHIEF ENGINEER	DWG. NO. STD. WD-17-A
CHECKED	R.E. 7/98		REVISION:	APPENDIX B
REVIEWED	R.C. 7/98		CITY OF PALO ALTO, CALIFORNIA	