



**NOTES:**

1. ALL DEVICES SHALL BE APPROVED BY WATER-GAS-WASTEWATER UTILITIES DEPARTMENT.
2. THE DEVICE SHALL BE INSTALLED ON THE OWNER'S PROPERTY AND ADJACENT TO THE METER.
3. INSPECTION BY UTILITIES CROSS CONNECTION INSPECTOR IS REQUIRED FOR SUPPLY PIPE BETWEEN THE METER AND THE VALVES.
4. APPROVED DCD ASSEMBLIES, SEE SECTION 02660 OF THESE STANDARDS

BY	DATE	<b>DOUBLE CHECK DETECTOR - DCD FOR AUTOMATIC FIRE SPRINKLER STANDARD DETAIL</b>	APPROVED: OCTOBER, 30 1992	SCALE: NONE
DRAWN	J.J. 9/92		<i>Roger Cwiak</i> ROGER CWIAK CHIEF ENGINEER	DWG. NO. STD. WD-18
CHECKED	J.J. 9/92		34533 R.E. NO.	
REVIEWED	R.E. 4/98		REVISION: OCTOBER 7, 2004	APPENDIX B
		CITY OF PALO ALTO, CALIFORNIA		

148